				E	XHA	UST	FA	N S	SCH	IED	JLE							
ITEM	MANUFACTURER	AREA	LOCATION	FAN TYPE	AIR QTY	ESP IN	B.H.P.	FAN	MOTOR		OR	SONES	DRIVE	APPROX. UNIT WT.=	DETAIL	REMARKS		
NO.	& MODEL NO.	SERVED	LOCATION	TAN TIFE	ČFM	H <sub>2</sub> O	(W)	RPM	RPM	MIN. H.P.	V-ø-HZ			WI.= LBS.				
EF 1	LOREN COOK 120C2B ACEB	PRESS BOX	PRESS BOX ROOF	DOWNBLAST CENTRIFUGAL	660	0.5	0.129	1153	1725	1/6	115–1–60	6.7	BELT	70	1 M300	123456		
REM.	ARKS HERMAL OVERLOAD	MOTOR	4 AUTOMATIC BELT TENSIONER				6 INTERLOCK EXHAUST FAN WITH THERMOSTAT											
② BACK DRAFT DAMPER		5 FAN SPEED CONTROLLER																
3 R	OOF CURB-FACTOR	RY FURNISHED																

MARK MARK OR OR SYMBOL SYMBOL	MARK OR SYMBOL		APPLICABLE NOTES
ONE WAY FLOW  THREE WAY FLOW  TWO WAY FLOW  TOUR WAY FLOW  CR CLG. EXHAUST AIR DEVICE	S.W.S. SIDEWALL SUPPY AIR DEVICE  S.W.R./S.W.E SIDEWALL RETURN OR EXHAUST AIR DEVICE  CR CLG. RETURN AIR DEVICE	SIZE MODULE FACE FOR ALL LAY-IN CEILINGS. CFM'S AS INDICATED ON PLANS.  PAINT ALL VISIBLE DUCTWORK BEHIND AIR DEVICES MATTE BLACK PROVIDE BOWDEN	(1) UNLESS OTHERWISE NOTED ON DRAWINGS. (2) VERIFY AND PROVIDE CORRECT BORDER TYPE FOR REQUIRED APPLICATION. (3) NOISE LEVEL NOT TO EXCEED NC 25 (U.O.N.).

2100 East Route 66, Suite 101 Glendora, CA 91740 T. 626.650.0350 F. 626.650.0352 www.pbsengineers.com Mechanical Electrical Plumbing | Consulting Engineers

Job No. 2014—115—00

IDENTIFICATION STAMP DIVISION OF THE STATE ARCHITECT OFFICE OF REGULATION SERVICES A# 03-117117

FILE# 19-H10 **REVISIONS:** DESCRIPTION Addendum A 4-5-2017

01-23-2017 DATE ISSUED: 2014-40163 PROJECT NO:

SHEET NUMBER:

**MECHANICAL EQUIPMENT SCHEDULES** 



